

Two drinking fountains and a Family and Consumer Science sink tested above the action level and were shut off, labeled as non-drinking water, and were replaced. The new fixtures were retested and results were below the action level. These outlets may be used as drinking/cooking water again.

Two slop sinks tested above the action level. These sinks are not accessible to students and are deemed non-potable water and are not required to be replaced.

A science lab sink tested above the action level. This sink is deemed non-potable water but was re-flushed and tested below the action level. Students are not allowed to drink water out of science lab sinks.

A classroom sink tested above the action level and was permanently shut off since it is not used.